

LOCATION 1776 Hoffman Rd CITY Castroville
BETWEEN Hoffman STREET & dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>52'</u>	<u>11-9-96</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>-0-</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>52'</u>			

ENTERS 1776 BRANCHED INTO -
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 447' n. of CH


PRESSURE TEST @ 100 PSI FOR 1/2 HRS BY JP Hoffman

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1986

DEPTH 3 FT 0 IN LOCATION _____

A P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	