

LOCATION 2095 Hoffman Rd CITY Easton

BETWEEN Tenn. Dr. STREET & Lawrence STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>1.00</u>	<u>10-17-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>38</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>62</u>			

ENTERS: 2095 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside of house


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By Bennett

MAIN-SIZE 6 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1963

DEPTH: 2 Ft. 6 In. LOCATION 10' W of Cylt

"A" P/S READING 1010 TOTAL ANODES 1# _____ 17# _____ L.R. # 00462456

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY