

LOCATION 2417 Hoffman St CITY GASTONIA

BETWEEN Malotte Ln. STREET & Blair St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	85'	3-10-95		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	75'			

ENTERS: 2417 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 464' N. of center of

Malotte Ln.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFLE

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1971

DEPTH: 3 Ft. 0 in. LOCATION 17' W. of center of Hoffman St

"A" P/S READING 1.3 TOTAL ANODES 1* 0 17* 0 L.R. # 89710

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY