

LOCATION

1018 Holland Ave

CITY

Cassport

BETWEEN

Westwood Ave

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	P	62'	10-6-95		
MAIN TO PROP. LINE	3/4'	P	5'			
PROP. LINE TO BLDG.	3/4'	P	57'			

ENTERS:

1018

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

262' NE. of center of

Westwood Ave

PRESSURE TEST: @

100

psi

For

1/4 Hrs.

By

S. Burkholder

MAIN-SIZE

2'

C.I.

BARE STEEL

COATED STEEL

✓

PLASTIC

YEAR INSTALLED

DEPTH:

3 Ft.

0 In.

LOCATION

28' NW of center of Holland Ave

"A" P/S READING

1.3

TOTAL ANODES 1*

2


17*

0

L.R. #

487869

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	