

LOCATION 1029 Holland Ave CITY Conover  
BETWEEN Glen STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Gal</u>		<u>Banded Insulated Muller Tee</u>		
MAIN TO PROP. LINE				<u>3-16-00</u>		
PROP. LINE TO BLDG.						

ENTERS: 1033 BRANCHED INTO: 1031-1029

TAP SIZE: • PRESSURE        PSI INCHES W.C. LOCATION


PRESSURE TEST: @        PSI FOR        HRS. BY       

MAIN SIZE 3/4 C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1960

DEPTH: 1 FT. 6 IN. LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 17 L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SP-501</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY