

LOCATION 1765 Hollandale DR CITY CASTONIA

BETWEEN Montrose DR STREET & Pine ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>	<u>12-23-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>81'</u>			

ENTERS: 1765 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 346' N. of center of

Pine ridge DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstake

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION 81' W. of center of Hollandale DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 737287

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY