

LOCATION 1768 Hollandale Dr CITY Gastonia
BETWEEN Pine ridge STREET & Montrose STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>106'</u>	<u>1-5-95</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>58</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>58'</u>			

ENTERS: 1768 BRANCHED INTO: 6
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 365' N of Lot
Pine ridge Dr

PRESSURE TEST: @ 160 psi For 1/4 Hrs. By BC
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1995
DEPTH: 3 Ft. In. LOCATION 22' w of Lot Hollandale Dr

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 00060543

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY