

LOCATION 2034 Hollandale Dr. CITY Gastonia
BETWEEN Landsdowne Dr. STREET & Montrose Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>116'</u>	<u>8-22-00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>39'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>77'</u>			

ENTERS: 2034 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 422' E. Landsdowne Dr.
13' S. Hollandale Dr.

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY C.R.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1961

DEPTH: 3 FT. 6 IN. LOCATION 13' S. Hollandale Dr.

"A" P/S READING .9 TOTAL ANODES 1# - 17# - I.R. # -

REMARKS: Ran New 3/4" plastic service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.95v</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

