

LOCATION 2318 Hollandale Dr. CITY GASTONIA
BETWEEN N. New Hope STREET & Landsdowne STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105'</u>	<u>4-9-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>			

ENTERS: 2318 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 35' W of Caf Landsdowne

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998
DEPTH: 3 FT. 0 IN. LOCATION 24' N of Caf Hollandale Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 249692

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY