

LOCATION

2324 Hollandale Dr.

CITY

GASTONIA

BETWEEN

Pine Ridge Dr.

STREET &

LANDSDOWN DR

STREET

	SIZE	TYPE	LENGTH'	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	57'	1-28-03		
MAIN TO PROP. LINE	5/8"	P	4'			
PROP LINE TO BLDG	5/8"	P	53'			

ENTERS

2324

BRANCHED INTO

TAP SIZE

3/4"

PRESSURE

60

PSI

INCHES W C

LOCATION

96' S. of path
of Hollandale Dr

PRESSURE TEST @

100

PSI

FOR

14

HRS

BY

SLH

MAIN-SIZE

2"

C I

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1986

DEPTH

3 FT

IN

LOCATION

20' W. of path of Pine Ridge Dr.

"A". P/S READING

P

TOTAL ANODES 1#

0


17#

0

LR #

37823

REMARKS



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	