

LOCATION 304 Hollow Pine DR CITY Canton, MA

BETWEEN Creek Ridge DR STREET & Cut-de-Sue STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>4-23-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>67'</u>			

ENTERS 304 BRANCHED INTO _____

TAP SIZE. 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 18' S. of center of Hollow Pine CT.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 286 S.W. of center of Creek Ridge DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 268367

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	