

LOCATION 328 Hollow Pine Ct. CITY GASTON
BETWEEN Creek Ridge Dr STREET & Cal. de - St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>6-12-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS: 328 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 100' SW of center

of Creek Ridge Dr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 17' NW of center of Hollow Pine Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 535164

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Moin	<u>E</u>	

