

LOCATION 1203 HOOPER AVECITY GASTONIABETWEEN VANCESTREET & SPENCER

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	75'	9-23-95	9-23-95	
MAIN TO PROP. LINE			35'		157' 3/4" (fw)	
PROP. LINE TO BLDG.			40'		9-24-66	

ENTERS: 1203

BRANCHED INTO:

TAP SIZE: 3/8PRESSURE: 60 P.S.I. _____ INCHES W.C.LOCATION 13' N OFHOOPERPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M PARKERMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1970DEPTH: 3 Ft. 0 In.LOCATION 152' W OF VANCE"A" P/S READING 1.4TOTAL ANODES 1* 0 17* 0L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY