

LOCATION 1204 HooperCITY CagataryisBETWEEN FLOYDSTREET & dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	78'	9-21-94		
MAIN TO PROP. LINE	1"	"	13'			
PROP. LINE TO BLDG.	1"	"	65'			

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

PSI

INCHES W.C.

LOCATION 13' N.E. of C ofPRESSURE TEST: @ 100 PSIFOR 1/4 HRS.BY JPHooperMAIN SIZE 2"

C.I.

BARE STEEL

COATED STEEL ☒

PLASTIC


YEAR INSTALLED 1961DEPTH: 2 FT.0 IN

LOCATION

"A" P/S READING 1.40TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OK</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	