

LOCATION 1209 Hooper Ave CITY CASTANA  
BETWEEN VANCE ST STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>20'</u>	<u>6-7-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>20'</u>			

ENTERS: 1207 BRANCHED INTO: 1209  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 247° W. of center of Vance St

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSTUTH  
MAIN-SIZE 3/4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996  
DEPTH: 2 FT. 0 IN. LOCATION 52' S. of center of Hooper Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 283428

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY