

LOCATION 1209 Hooper Ave CITY Canton

BETWEEN Vance St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>	<u>6.7.96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>			

ENTERS: 1209 BRANCHED INTO: 1207

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 227' W. of center
of Vance St


PRESSURE TEST: @ 60 PSI FOR 1/4 HRS. BY S. Hults

MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1973

DEPTH: 1 FT. 6 IN. LOCATION 14' S. of center of Hooper Ave

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # 283408

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY