

LOCATION 1520 Hoyle StCITY GastoniaBETWEEN Lindwood

STREET

& Garland

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>3/4</u>		<u>10/20/95</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1520BRANCHED INTO: -TAP SIZE: 3/8

PRESSURE

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @

PSI

FOR

HRS.

BY

MAIN-SIZE 2"

C.I.


BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1959DEPTH: 2 FT. 0 IN.

LOCATION

"A" P/S READING 1.200TOTAL ANODES 1# -17# -L.R. # -REMARKS: Bonded Service - Take I/S out of Book

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R: sex</u>	<u>1.200</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY