

LOCATION 109 E. Hudson Blv. CITY Gastonia

BETWEEN S. York Rd. STREET & Gardner St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>263'</u>	<u>8-2-02</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>	<u>"</u>		
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>263'</u>	<u>"</u>		

ENTERS. 109 BRANCHED INTO: 0

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 196' East of
center of S. York Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

~~MAIN~~ SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 2' FT 0" IN LOCATION 164' south of center of E. Hudson Blv.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00217850

REMARKS: New Plastic service
(off of 3/4" plastic stub)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>rise</u>