

LOCATION 1110 E. Hudson Blvd. CITY GASTONIA
BETWEEN Union Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>158'</u>	<u>5-24-03</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>70'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>88'</u>			


ENTERS 1110 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 64' N. of center of E. Hudson Blvd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SGK
MAIN-SIZE 3/4" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 45' W. of center of Driveway

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 126188

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	