

LOCATION 2212 Hudson Blvd. CITY Castroville

BETWEEN Union Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>52'</u>	<u>6-8-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>52'</u>			

ENTERS: 2212 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 564' E. of center of

Union Rd


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. GUFFORD

MAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 25' S. of center of Back Alley

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 259389

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY