

LOCATION 309 Huffman Rd CITY Craston, IA
 BETWEEN Goble St STREET & Birchfield Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>12-22-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>"</u>		

ENTERS 309 Huffman Rd. BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 209 East

g center of Goble St.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.F.
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1969
 DEPTH. 3' FT 0" IN LOCATION 11' south of center of Huffman Rd.

"A" P/S READING 1.4 TOTAL ANODES 1# Ø 17# Ø LR # 00023874

REMARKS New 3/4" Plastic service



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>