

COPY

LOCATION 3336 Huntingwood Ct. CITY GASTONIA
 BETWEEN Forest Creek Ct. STREET & End of Calderack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>5/8"</u>	<u>Plastic</u>	<u>70'</u>	<u>9-11-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>45'</u>			

ENTERS 3336 BRANCHED INTO 0
 TAP SIZE: 3/4 PRESSURE LED PSI _____ INCHES W/C LOCATION 376' S of C of Forest Creek Ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 18' E of C of Huntingwood Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 I.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>