

LOCATION 3360 Hunting Wood Ct. CITY Gastonia
BETWEEN Forest Creek Ct. STREET & Strong Box Ln. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	57'	7-3-02		
MAIN TO PROP LINE	5/8"	P	6'	"		
PROP LINE TO BLDG	5/8"	P	51'	"		

ENTERS 3360 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 528' south of curb of Forest Creek Ct.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3' FT 0" IN LOCATION 18' East of curb of Hunting Wood Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 175915

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>11.5</u>