

LOCATION 3330 Huntingwood CT CITY Castonia
BETWEEN Forest Creek Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/8</u>	<u>P</u>	<u>75'</u>	<u>8-20-01</u>		
MAIN TO PROP LINE	<u>3/8</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/8</u>	<u>P</u>	<u>75'</u>			

ENTERS 3330 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 257' S. of center of Forest Creek Ct.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.B.L.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 20' E. of curb at Huntingwood Ct.

"A" P/S READING P TOTAL ANODES I# 17# LR # 672263

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	