


COPY

LOCATION 3401 Hunting wood Ct CITY GASTONIA
 BETWEEN Forest Creek Ct STREET & End of Calder Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>100'</u>	<u>7-25-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>			

 ENTERS 3401 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES WC LOCATION 848' S of C of Forest Creek Ct
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001
 DEPTH 3 FT 6 IN LOCATION 19' E of C of Hunting wood Ct
 "A" P/S READING Plastic n/a TOTAL ANODES 1# 0 17# 0 LR #
 REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	12.5V
P/S Pipeline Lead - White Existing Main	E	Plastic