

LOCATION 3433 Hunting Wood Ct. CITY BARTONIA  
BETWEEN Forest Creek Ct. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>72'</u>	<u>7-25-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>62'</u>			

ENTERS 3433 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 1138' S of C of Forest Creek Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 42' W of C of Hunting Wood Ct. Culdesack

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser
P/S Pipeline Lead - White Existing Main	E	Plastic