

LOCATION 1181 Huntsmore DrCITY GastoniaBETWEEN Bradywine

STREET &

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>187'</u>			<u>6-18-97</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>42'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>65'</u>			

ENTERS: 1181 Huntsmore DrBRANCHED INTO: 1189 Huntsmore DrTAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION —PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SSMAIN SIZE 3/4 Stub C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1969DEPTH: 1 FT. 4 IN. LOCATION —"A" P/S READING 1.2TOTAL ANODES 1# — 17# —I.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plade</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY