

LOCATION 1301 Huntsmoor DR CITY Gastonia

BETWEEN S. New Hope Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>	<u>4-4-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>30'</u>			

ENTERS. 1301 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 153' S. of center of Huntsmoor Dr


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY Suf

PIPE SIZE 3/4" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1983

DEPTH: 1 FT 0 IN LOCATION 178' E. of center of S. New Hope Rd.

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 275278

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	