

LOCATION 712 I.D.A. St CITY GASTON, A

BETWEEN Dead End STREET & Hemlock STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>A</u>	<u>46'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>A</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>A</u>	<u>41'</u>			<u>2-10-99</u>

ENTERS 712 BRANCHED INTO 0

TAP SIZE 3/4 San PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 1 hr BY LP

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1957

DEPTH 2 FT 6 IN LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 7 LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	E	