

LOCATION 2756 Independence Way CITY Gastonia  
BETWEEN Shelwell dr STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>72'</u>	<u>4-27-95</u>		
MAIN TO PROP. LINE	<u>1/1</u>	<u>11</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>66'</u>			

ENTERS: 2756 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 31' W. of a of

Independence way


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1988

DEPTH: 2 Ft. 4 In. LOCATION

"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY