

LOCATION 1299 Indigo Run CITY BASTONIA
BETWEEN LAVINGTON CT. STREET & End of Caldesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>70'</u>	<u>4-17-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>9'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>61'</u>			

ENTERS: 1299 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 70' W of C of Lavington Ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 FT. 6 IN. LOCATION 19' S of C of Indigo Run

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 185699

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & location	Lead	.Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		