

LOCATION 1319 INDEGO Run LN. CITY GASTONIA

BETWEEN LAMINGTON CT. STREET & PLANTATION TRL STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	65'	1-10-95		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	65'			

ENTERS: 1319 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 22' E of center of

LAMINGTON CT.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huff

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 18' S. of center of INDEGO Run LN.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 582832

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY