

LOCATION 1378 Indigo Run CITY GASTAVILA

BETWEEN PLANTATION TRC STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>120'</u>	<u>2-6-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS: 1378 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 190' W. of center of

PLANTATION TRC


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. H. H. Smith

MAIN-SIZE 2' C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 18' S. of center of Indigo Run

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 51600

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY