

LOCATION 1200 INDUSTRIAL AVE. CITY GASTONIA
BETWEEN HANCOCK STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>113'</u>	<u>12.7.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>71</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>42</u>			

ENTERS 1200 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION S. side of 1200

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GK

MAIN SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 1997

DEPTH 4 FT IN 6 LOCATION S. side of Hancock

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

