

LOCATION 1208 INDUSTRIAL AVE. CITY GASTONIA  
BETWEEN HANCOCK STREET & DEAD END STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>17'</u>		<u>6-9-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>14'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION EAST SIDE OF 1208

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 97  
DEPTH: 4 FT. IN. LOCATION WEST SIDE OF INDUSTRIAL AVE.

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY