

LOCATION 247 INGLISH DR. CITY CRAVATT

BETWEEN CRAVATT CT STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>93'</u>	<u>7-6-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS. 247 BRANCHED INTO

TAP SIZE. 1/2 PRESSURE 62 PSI INCHES WC LOCATION 876' N. of center of CRAVATT CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SCH

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1998

DEPTH. 3 FT 0 IN LOCATION 17' E of center of INGLISH DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 544948

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	B	