

LOCATION 257 Ingouish Dr. CITY Boston MA
BETWEEN Grovant Ct. STREET & Keltie Meadows STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	74'	4-27-01		
MAIN TO PROP LINE	3/4"	P	12'	"		
PROP LINE TO BLDG	3/4"	P	62'	"		

ENTERS 257 BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 739' North


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Ø center of Grovont Ct.
D. Wood

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 20' East of center of Ingouish Dr.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø L R # 318699

REMARKS New 3/4" P. Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>plastic</u>
P/S Pipeline Lead White Existing Main	E	<u>rise</u>