


COPY

4/27/00

LOCATION <u>271 Ingomish Dr.</u>			CITY <u>SAINTONIA</u>			
BETWEEN <u>Grouant Dr.</u>			STREET & <u>Cape Breton TRL.</u>		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>	<u>1-27-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>70'</u>			
ENTERS <u>271</u>			BRANCHED INTO <u>0</u>			
TAP SIZE <u>1/2</u>	PRESSURE <u>60</u> PSI	INCHES W/C		LOCATION <u>296' W of C of Grouant Dr.</u>		
PRESSURE TEST @ <u>100</u> PSI FOR <u>1/4</u> HRS BY <u>AL</u>						
MAIN SIZE <u>2"</u>	C I	BARE STEEL	COATED STEEL	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED <u>1998</u>	
DEPTH <u>3</u> FT <u>6</u> IN	LOCATION <u>21' N of C of Ingomish Dr.</u>					
A P/S READING <u>PLASTIC N/A</u>			TOTAL ANODES 1# <u>0</u> 17# <u>0</u>		I.R. # <u>00058496</u>	
REMARKS						



Test Station		
Reading & Location	Lead	Voltage
P/S Pipeline lead Red New Service	S	Riser
P/S Pipeline lead White Existing Main	E	PLASTIC