

LOCATION 242 INCONISH DRIVE CITY GA STONIA  
BETWEEN NO NAME STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>115</u>	<u>2-2-98</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>40</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>75</u>			

ENTERS: 242 BRANCHED INTO  
TAP SIZE: 3/4 PRESSURE 60 PSI INCHES WC LOCATION 16' E OF INCONISH

PRESSURE TEST @ 100 PSI FOR 44 HRS BY M. PARKER  
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 19  
DEPTH: 3 FT 0 IN LOCATION 1078' S OF NO NAME

"A" P/S READING P TOTAL ANODES 1# 17# LR # 00035001

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>7-15ER</u>
P/S Pipeline Lead - White Existing Main	E	

