

LOCATION 909 IRIS Dr. CITY Boston
BETWEEN Andy Ln. STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	30'	8-22-00		
MAIN TO PROP LINE	3/4	P	5'			
PROP LINE TO BLDG	3/4	P	25'			

ENTERS 909 BRANCHED INTO
TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 85' N. IRIS Dr.
25' W. Andy Ln.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY CR.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1971

DEPTH 3 FT 6 IN LOCATION 25' W. Andy Ln.

"A" P/S READING 1.3 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS Ran New 3/4" Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P.P. Ser
P/S Pipeline Lead - White Existing Main	E	