

LOCATION 3311 Ivy Creek Rd. CITY CANTONIA

BETWEEN Mossbank Pl. STREET & Cut-de-Sk STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>147'</u>	<u>1-26-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>142'</u>			

ENTERS: 3311 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 106' S. of center of

Mossbank Pl.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Guffe-Stall

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1989

DEPTH. 3 FT. 0 IN LOCATION 18' W. of center off Ivy Creek Rd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 35081

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY