

LOCATION 810 S JACKSON ST CITY GAST

BETWEEN GARRISON BLVD STREET & EIGHTH AV STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>147</u>			<u>4-9-97</u>
MAIN TO PROP. LINE	<u>1 1/2"</u>	<u>"</u>	<u>47</u>			
PROP LINE TO BLDG.	<u>1 1/2"</u>	<u>"</u>	<u>100</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE. 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 20' west from (C) of JACKSON


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY gfw

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION West Side of Jackson St

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY