

LOCATION 814 JACKSON ST. CITY GASTONIA

BETWEEN Eighth Ave. STREET & CARRISON BRD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>85'</u>	<u>1-20-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>40'</u>			

ENTERS: 814 BRANCHED INTO:

TAP SIZE 3/4" PRESSURE 60 PSI          INCHES W/C LOCATION 242' N. of center of

Eighth Ave.


PRESSURE TEST: @ 100 PSI FOR 44 HRS BY S. HUFFSTETTER

MAIN-SIZE 4" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 22' W. of center of JACKSON ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 35312

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY