

LOCATION 829 S. JACKSON STCITY CASSTBETWEEN EIGHTH AV

STREET &

TENTH AV

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>68'</u>		<u>4-15-97</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>~</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>66'</u>			

ENTERS SAME


BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION 19' WEST FROM (C) OF JACKSONPRESSURE TEST: @ 100 PSIFOR 1/4 HRSBY JmMAIN-SIZE 4"C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1997DEPTH: 3 FT 0 INLOCATION WEST SIDE OF JACKSON"A" P/S READING PTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY