

LOCATION 832 S JACKSON STCITY GASTBETWEEN EIGHTH AVSTREET & TENTH AV

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|-----------|-----------|----------------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>30</u> | | <u>4-15-97</u> | |
| MAIN TO PROP. LINE | <u>"</u> | <u>"</u> | <u>15</u> | | | |
| PROP. LINE TO BLDG. | <u>"</u> | <u>"</u> | <u>15</u> | | | |

ENTERS: SAMEBRANCHED INTO: 828 S JACKSON STTAP SIZE: 3/4"PRESSURE 60 PSI


INCHES W.C.

LOCATION 46' EAST FROM (C) OF JACKSONPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY gr

~~PIPE~~ SERVICE SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN LOCATION "A" P/S READING PTOTAL ANODES 1# — 17# —L.R. # —

REMARKS:



Test Station

| Reading & Location | Lead | Volts |
|--|----------|-------|
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY