

LOCATION 1204 JACKSON RD. CITY GASTONIA

BETWEEN JACKSON ROAD STREET & JACKSON ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>51</u>		<u>12-08</u>	<u>97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>31</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>20</u>			

ENTERS: BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 94' NORTH OF JACKSON RD.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997

DEPTH: 3 FT IN. LOCATION 12' WEST OF JACKSON ST.

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>AR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY