

LOCATION 1306 JACKSON RD CITY COLUMBIA

BETWEEN Twelfth Ave STREET & Home TRAIL STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>54'</u>		<u>OK</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>1'</u>		<u>5-28-96</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>53'</u>			

ENTERS: 1306 BRANCHED INTO: 6

TAP SIZE: 3/4 In. PRESSURE 20 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 105 PSI FOR 14 HRS. BY EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL ✓ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1956

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING .5 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Alaska</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		

