

LOCATION 1315 1/2 JACKSON ROAD CITY GASTONIA  
BETWEEN HILLCREST STREET & 12<sup>TH</sup> STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64</u>		<u>01/30/98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>10</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>54</u>			


ENTERS: 1315 1/2 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 286' E of Hillcrest

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY NS  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997

DEPTH: 3 FT. IN LOCATION 20' NORTH of LINBERGER

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>X R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY