

LOCATION 1324 JACKSON ROADCITY GASTONIABETWEEN HILLCREST

STREET &

HOME TRAIL

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>137</u>		<u>01-80-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>132</u>			


ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 255' EAST of HillcrestPRESSURE TEST @ 100 PSI FOR 1/4 HRS BY N.S.MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 4 FT. IN LOCATION 22' NORTH OF JACKSON RD

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY