

LOCATION 1326 JACKSON ROAD CITY GASTONIA  
BETWEEN Hillcrest STREET & Home TRAIL STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>153'</u>		<u>01-22-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>150'</u>			

ENTERS: BRANCHED INTO:  
TAP SIZE. 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 104' E of Hillcrest

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS  
MAIN-SIZE 3/4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997  
DEPTH: 4 FT. IN LOCATION 24' NORTH OF JACKSON ROAD

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: INSTALLED 85' OF NEW 3/4" PLASTIC SERVICE, TIED OVER 68 FEET.  
TOTAL 153' FEET.

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>XR</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		